

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0085:191 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Services Inc., 4128 North Freeway Blvd., Sacramento, CA 95834-1219
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Model 472491 AC Communicator Module. This unit is designed to transmit reports to the central station when it is directly wired to the telephone line. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

XLF: 7300-0078:195

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager